



RESOLUTION

Number: R09/09/15-1

Regulations Hearing Committee 2015

Moved by: Mark Burnahm

Seconded by: Duncan Abbott

Resolved, That Ontario Regulation 153/06 Application Number W14-76 be approved with the following conditions:

1. The permit holder shall maintain a copy of the permit on site and shall ensure that all individuals involved in carrying out the work are aware of the permit and its conditions.
2. The measures and stipulations detailed in Section 5.3.6 in *Lakes and Rivers Improvement Act Application Enerdu Generating Station Expansion Project Engineering Report - Revision 1* (July 2015) prepared by HydroSys Consultants will be followed during the construction period.
3. Prior to the start of construction, the contractor will prepare and submit a sedimentation and erosion control and dewatering plan for use during the construction period to the MVCA. It will be the owner's responsibility to ensure appropriate implementation of the plan.
4. It will be the proponent's responsibility to ensure that the coffer dams are inspected daily and that any maintenance is carried out as required.
5. The permit does not allow right-of-ways, for construction access, to be established on property owned by others without prior approval of the landowner.
6. Prior to the start of construction, the proponent will submit a revised construction schedule to the MVCA.
7. All work shall be carried out in such a manner that will prevent the release of construction and excavation wastes, overburden soil and any other substances deleterious to aquatic life into the Mississippi River.

8. To confirm that the proposed works have been completed as approved, the proponent will submit as-build drawings for the project to the MVCA.
9. Permit will be valid until September 9, 2019 to address potential construction delays due to possible adverse environmental conditions.

Carried September 9, 2015

John Karau
Chairman